

May 8, 2024

Ms. Sharri Pittman  
Biome STEAM School  
Director of Operations  
[spittman@thebiomeschool.org](mailto:spittman@thebiomeschool.org)

**RE: Biome STEAM Schools – Drinking Water Testing Services**  
**4471 Olive Street**  
**St. Louis, MO 63108**

Dear Ms. Pittman:

Blackstone Environmental Inc., (Blackstone) has been contracted by the Biome STEAM School to provide lead in drinking water sampling for the high-priority potable water sources throughout the school. The objective of the sampling was to determine the lead concentrations in the high priority potable water sources throughout the school and to identify sources exceeding the Missouri SB681 Action Level of 5 parts per billion (ppb).

### **Background**

Testing and reporting has been conducted in accordance with Missouri State Statute 160-077, Get the Lead Out of School Drinking Water Act, and included sampling of potable water fixtures used for drinking or food preparation including water fountains, faucets, taps, ice making machines, hot drink machines, and outlets used for dispensing water for cooking or for cleaning cooking and eating utensils.

### **Field Sampling**

Field sampling procedures included preparing an inventory of drinking water outlets and outlets that are used for dispensing water for cooking or for cleaning cooking and eating utensils.

Each water source was flushed for a minimum of five minutes. Signage was then attached to the source to prevent it from being used prior to sample collection. Between 8 and 18 hours after the source was flushed, Blackstone personnel returned to collect a water sample into laboratory supplied 250-mL sample containers for analysis of total lead concentration by EPA Method 200.8. New nitrile gloves were worn for each sample collection. Labels were prepared and affixed to each sampling container stating the sample location, technicians name, and date and time of sample collection. Field forms were prepared to document pertinent information including sample identification, type of source, time flushed, and time sampled. Field information forms are included in Attachment A.

Once sampling was complete, the samples were transferred under proper chain-of-custody procedures to TekLab, Inc. of Collinsville, Illinois for analysis.

## Analytical Summary

A total of 53 water samples were collected from Biome STEAM School at 4471 Olive Street. A summary table is included in Attachment B. Of the 53 samples collected, 6 exceeded the Missouri SB681 Action Level for lead of 5 ppb as shown in the table below.

### Summary of Lead Results Exceeding Action Levels

Sample ID	Location Description	Lead Concentration
B-Ann-S3	Sink in Room 308	487
B-Ann-S4	Sink in Room 308	8.1
B-Ann-S7	Sink in Room 307	6.3
B-Ann-S8	Sink in Room 307	6.6
B-Ann-S17	Sink in Room 305	6.6
B-Ann-S25	Sink in Room 303	8

\*Concentrations in µg/L

A copy of the laboratory analytical report is included as Attachment C.

## Recommendations

Recommendations for those water sources that exceed the action levels include additional filtration, removing and repairing piping and/or fixtures that may be the source of elevated lead levels, or removing the effected sources from service.

If either of the first two options are chosen, the source will have to be resampled to verify that the lead concentrations are below the action level of 5 ppb.

## Limitations

This report was prepared in accordance with that level of skill and care ordinarily exercised by other members of Blackstone's profession practicing in the same locality and under similar conditions when the services were provided. No warranties, express or implied, are intended or made.

## Closing

If you have any questions, or need further assistance, please contact Tyler Huff at (314) 943-0895 or Ed Shepard at (314) 392-7870.

Respectfully,  
**BLACKSTONE ENVIRONMENTAL, INC.**



Tyler Huff, E.I.T.  
Project Engineer



Edward A. Shepard Jr., P.E.  
Senior Project Manager

Enclosures Attachment A – Field Forms  
Attachment B – Summary Table  
Attachment C – Laboratory Analytical Report

**ATTACHMENT A**

---

**Biome STEAM School  
Field Forms**

Date Purged 3/23/2024  
 Date Sampled 3/28/2024

School: Bione STEAM

Team TH

Sample ID = School abbrev + Floor + Type + Test number (Ex: MEIDF1)

Test #	Floor #	Sink (S)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
1	Ann	X			Room 308 C/W from Door (All 5 sinks sampled)	15:15	7:05
2						15:15	7:06
3						15:16	7:07
4						15:16	7:08
5						15:16	7:08
6					Room 307 C/W from Door (All 5 sinks sampled)	15:30	7:12
7						15:30	7:12
8						15:31	7:13
9						15:31	7:13
10						15:31	7:14
11					Room 306 C/W from Door (Front Left Not Sampled)	15:37	7:20
12						15:37	7:20
13						15:38	7:21
14						15:38	7:21
15					Room 305 C/W from Door (Front Right Not Sampled)	15:43	7:24
16						15:43	7:24
17						15:44	7:25
18						15:44	7:25
19					Room 304 C/W from Door (All 5 sinks sampled)	15:50	7:29
20						15:50	7:29
21						15:51	7:30
22						15:51	7:30
23						15:51	7:31
24					Room 303 C/W from Door (All 5 sinks sampled)	15:57	7:36

Date Purged 3/23/2024  
 Date Sampled 3/28/2024

School: Biome STEAM

Team TH

Sample ID = School abbrev + Floor + Type + Test number (Ex: ME1DF1)

Test #	Floor #	Sink (S)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
25	Ann	X			Room 303 (CU From Door (2nd-5th))	15:52	7:36
26		X				15:54	7:37
27		X				15:54	7:37
28		X				15:58	7:38
29			X		Water Fountain, Left	16:04	7:42
30			X		Water Fountain, Right	16:04	7:42
31			X		Water Fountain, Bottle Filler	16:04	7:43
32		X			Boy's Bathroom Farthest From Door (3 Total)	16:13	7:48
33					Middle Sink	16:13	7:48
34					Closest to Door	16:13	7:49
35					Girl's Bathroom Farthest From Door (3 Total)	16:18	7:52
36					Middle Sink	16:18	7:52
37					Closest to Door	16:18	7:53
38					Staff Bathroom	16:23	7:56
39	1				Kitchen	16:30	8:01
40			X		Water Fountain, w/ Bottle Filler	16:35	8:05
41			X		Water Fountain, Near Front Door	16:35	8:05
42			X		Girl's Bathroom Farthest From Door (4 Total)	16:40	8:08
43						16:40	8:08
44						16:44	8:09
45					Closest to Door	16:44	8:09
46					Boy's Bathroom, Farthest From Door (4 Total)	16:50	8:12
47						16:50	8:12
48						16:56	8:13



**ATTACHMENT B**

---

**Biome STEAM School  
Summary Table**

Biome STEAM School  
Drinking Water Sampling Results

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
B-Ann-S1	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S2	3/28/2024	Lead	1.0	µg/L	1
B-Ann-S3	3/28/2024	Lead	487	µg/L	1
B-Ann-S4	3/28/2024	Lead	8.1	µg/L	1
B-Ann-S5	3/28/2024	Lead	2.9	µg/L	1
B-Ann-S6	3/28/2024	Lead	1.2	µg/L	1
B-Ann-S7	3/28/2024	Lead	6.3	µg/L	1
B-Ann-S8	3/28/2024	Lead	6.6	µg/L	1
B-Ann-S9	3/28/2024	Lead	1.5	µg/L	1
B-Ann-S10	3/28/2024	Lead	2.0	µg/L	1
B-Ann-S11	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S12	3/28/2024	Lead	1.9	µg/L	1
B-Ann-S13	3/28/2024	Lead	2.2	µg/L	1
B-Ann-S14	3/28/2024	Lead	1.3	µg/L	1
B-Ann-S15	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S16	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S17	3/28/2024	Lead	6.6	µg/L	1
B-Ann-S18	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S19	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S20	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S21	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S22	3/28/2024	Lead	2.3	µg/L	1
B-Ann-S23	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S24	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S25	3/28/2024	Lead	8.0	µg/L	1
B-Ann-S26	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S27	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S28	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-DF29	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-DF30	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-DF31	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S32	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S33	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S34	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S35	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S36	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S37	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S38	3/28/2024	Lead	< 1.0	µg/L	1
B-Ann-S39	3/28/2024	Lead	< 1.0	µg/L	1

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
B-Ann-DF40	3/28/2024	Lead	< 1.0	µg/L	1
B-1-DF41	3/28/2024	Lead	< 1.0	µg/L	1
B-1-S42	3/28/2024	Lead	< 1.0	µg/L	1
B-1-S43	3/28/2024	Lead	< 1.0	µg/L	1
B-1-S44	3/28/2024	Lead	< 1.0	µg/L	1
B-1-S45	3/28/2024	Lead	< 1.0	µg/L	1
B-1-S46	3/28/2024	Lead	< 1.0	µg/L	1
B-1-S47	3/28/2024	Lead	< 1.0	µg/L	1
B-1-S48	3/28/2024	Lead	< 1.0	µg/L	1
B-1-S49	3/28/2024	Lead	< 1.0	µg/L	1
B-2-S50	3/28/2024	Lead	< 1.0	µg/L	1
B-2-S51	3/28/2024	Lead	< 1.0	µg/L	1
B-2-DF52	3/28/2024	Lead	< 1.0	µg/L	1
B-2-DF53	3/28/2024	Lead	< 1.0	µg/L	1

µg/L: micrograms per liter

1 µg/L=1ppb

Bolded results indicate detection above reporting limits (>1 ppb)

Results in red indicate Action Level of 5 ppb for lead is exceeded (>5ppb)

**ATTACHMENT C**

---

**Biome STEAM School  
Laboratory Analytical Report**

May 02, 2024

Tyler Huff  
Blackstone Environmental, Inc.  
16292 Westwoods Business Parks Dr.  
Ellisville, MO 63021  
TEL: (314) 392-7870  
FAX:



Illinois	100226
Illinois	1004652024-2
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

**RE:** 3649

**WorkOrder:** 24032285

Dear Tyler Huff:

TEKLAB, INC received 53 samples on 3/28/2024 9:45:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley  
Project Manager  
(618)344-1004 ex 44  
[patrickriley@teklabinc.com](mailto:patrickriley@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 24032285

**Client Project:** 3649

**Report Date:** 02-May-24

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	9
Chain of Custody	Appended

**Client:** Blackstone Environmental, Inc.

**Work Order:** 24032285

**Client Project:** 3649

**Report Date:** 02-May-24

### Abbr Definition

\* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

**Client:** Blackstone Environmental, Inc.

**Work Order:** 24032285

**Client Project:** 3649

**Report Date:** 02-May-24

### Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)



## Case Narrative

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 24032285

**Client Project:** 3649

**Report Date:** 02-May-24

**Cooler Receipt Temp:** N/A °C

---

### Locations

---

#### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425

**Phone** (618) 344-1004

**Fax** (618) 344-1005

**Email** jhriley@teklabinc.com

---

#### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425

**Phone** (618) 344-1004

**Fax** (618) 344-1005

**Email** EHurley@teklabinc.com

---

#### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415

**Phone** (217) 698-1004

**Fax** (217) 698-1005

**Email** KKlostermann@teklabinc.com

---

#### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515

**Phone** (630) 324-6855

**Fax**

**Email** arenner@teklabinc.com

---

#### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214

**Phone** (913) 541-1998

**Fax** (913) 541-1998

**Email** jhriley@teklabinc.com



## Accreditations

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 24032285

**Client Project:** 3649

**Report Date:** 02-May-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Illinois	IEPA	1004652024-2	NELAP	4/30/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2025	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2025	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 24032285

Client Project: 3649

Report Date: 02-May-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>									
<b>Lead</b>									
24032285-001A	B-Ann-S1	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 17:48	03/28/2024 7:05
24032285-002A	B-Ann-S2	NELAP		1.0	1.0	µg/L	1	04/30/2024 17:52	03/28/2024 7:06
24032285-003A	B-Ann-S3	NELAP		1.0	487	µg/L	5	05/02/2024 3:21	03/28/2024 7:07
24032285-004A	B-Ann-S4	NELAP		1.0	8.1	µg/L	1	04/30/2024 17:56	03/28/2024 7:08
24032285-005A	B-Ann-S5	NELAP		1.0	2.9	µg/L	1	04/30/2024 18:25	03/28/2024 7:08
24032285-006A	B-Ann-S6	NELAP		1.0	1.2	µg/L	1	04/30/2024 18:54	03/28/2024 7:12
24032285-007A	B-Ann-S7	NELAP		1.0	6.3	µg/L	1	04/30/2024 18:29	03/28/2024 7:12
24032285-008A	B-Ann-S8	NELAP		1.0	6.6	µg/L	5	05/02/2024 3:25	03/28/2024 7:13
24032285-009A	B-Ann-S9	NELAP		1.0	1.5	µg/L	1	04/30/2024 18:33	03/28/2024 7:13
24032285-010A	B-Ann-S10	NELAP		1.0	2.0	µg/L	1	04/30/2024 18:37	03/28/2024 7:14
24032285-011A	B-Ann-S11	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 18:41	03/28/2024 7:20
24032285-012A	B-Ann-S12	NELAP		1.0	1.9	µg/L	1	04/30/2024 18:45	03/28/2024 7:20
24032285-013A	B-Ann-S13	NELAP		1.0	2.2	µg/L	1	04/30/2024 19:47	03/28/2024 7:21
24032285-014A	B-Ann-S14	NELAP		1.0	1.3	µg/L	1	04/30/2024 18:49	03/28/2024 7:21
24032285-015A	B-Ann-S15	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 19:18	03/28/2024 7:24
24032285-016A	B-Ann-S16	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 19:22	03/28/2024 7:24
24032285-017A	B-Ann-S17	NELAP		1.0	6.6	µg/L	1	04/30/2024 19:27	03/28/2024 7:25
24032285-018A	B-Ann-S18	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 19:31	03/28/2024 7:25
24032285-019A	B-Ann-S19	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 19:35	03/28/2024 7:29
24032285-020A	B-Ann-S20	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 19:39	03/28/2024 7:29
24032285-021A	B-Ann-S21	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 19:43	03/28/2024 7:30
24032285-022A	B-Ann-S22	NELAP		1.0	2.3	µg/L	1	04/30/2024 20:12	03/28/2024 7:30
24032285-023A	B-Ann-S23	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 20:16	03/28/2024 7:31
24032285-024A	B-Ann-S24	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 20:20	03/28/2024 7:36
24032285-025A	B-Ann-S25	NELAP		1.0	8.0	µg/L	1	04/30/2024 20:24	03/28/2024 7:36
24032285-026A	B-Ann-S26	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 20:28	03/28/2024 7:37
24032285-027A	B-Ann-S27	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 20:40	03/28/2024 7:37
24032285-028A	B-Ann-S28	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 20:32	03/28/2024 7:38
24032285-029A	B-Ann-DF29	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 20:36	03/28/2024 7:42
24032285-030A	B-Ann-DF30	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 21:05	03/28/2024 7:42
24032285-031A	B-Ann-DF31	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 21:09	03/28/2024 7:43
24032285-032A	B-Ann-S32	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 21:13	03/28/2024 7:48
24032285-033A	B-Ann-S33	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 21:18	03/28/2024 7:48
24032285-034A	B-Ann-S34	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 21:22	03/28/2024 7:49
24032285-035A	B-Ann-S35	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 21:26	03/28/2024 7:52
24032285-036A	B-Ann-S36	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 21:30	03/28/2024 7:52
24032285-037A	B-Ann-S37	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 21:59	03/28/2024 7:53
24032285-038A	B-Ann-S38	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 22:11	03/28/2024 7:56
24032285-039A	B-Ann-S39	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 22:15	03/28/2024 8:01
24032285-040A	B-Ann-DF40	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 22:19	03/28/2024 8:05
24032285-041A	B-1-DF41	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 22:23	03/28/2024 8:05
24032285-042A	B-1-S42	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 22:27	03/28/2024 8:08
24032285-043A	B-1-S43	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 22:52	03/28/2024 8:08
24032285-044A	B-1-S44	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 22:56	03/28/2024 8:09
24032285-045A	B-1-S45	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 23:00	03/28/2024 8:09
24032285-046A	B-1-S46	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 23:04	03/28/2024 8:12
24032285-047A	B-1-S47	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 23:09	03/28/2024 8:12
24032285-048A	B-1-S48	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 23:13	03/28/2024 8:13



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 24032285

Client Project: 3649

Report Date: 02-May-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>									
<b>Lead</b>									
24032285-049A	B-1-S49	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 23:17	03/28/2024 8:13
24032285-050A	B-2-S50	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 23:46	03/28/2024 8:17
24032285-051A	B-2-S51	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 23:50	03/28/2024 8:18
24032285-052A	B-2-DF52	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 23:21	03/28/2024 8:20
24032285-053A	B-2-DF53	NELAP		1.0	< 1.0	µg/L	1	04/30/2024 23:54	03/28/2024 8:21



# Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 24032285

Client Project: 3649

Report Date: 02-May-24

Carrier: Employee

Received By: WAO

Completed by:

*Amber Dilallo*

Reviewed by:

*Elizabeth A. Hurley*

On:

On:

28-Mar-24

01-Apr-24

Amber Dilallo

Elizabeth A. Hurley

Pages to follow: Chain of custody

Extra pages included

- Shipping container/cooler in good condition? Yes  No  Not Present  Temp °C **N/A**
- Type of thermal preservation? None  Ice  Blue Ice  Dry Ice
- Chain of custody present? Yes  No
- Chain of custody signed when relinquished and received? Yes  No
- Chain of custody agrees with sample labels? Yes  No
- Samples in proper container/bottle? Yes  No
- Sample containers intact? Yes  No
- Sufficient sample volume for indicated test? Yes  No
- All samples received within holding time? Yes  No
- Reported field parameters measured: Field  Lab  NA
- Container/Temp Blank temperature in compliance? Yes  No

*When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.*

- Water – at least one vial per sample has zero headspace? Yes  No  No VOA vials
- Water - TOX containers have zero headspace? Yes  No  No TOX containers
- Water - pH acceptable upon receipt? Yes  No  NA
- NPDES/CWA TCN interferences checked/treated in the field? Yes  No  NA

**Any No responses must be detailed below or on the COC.**

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

246322850

# CHAIN OF CUSTODY

pg. 1 of 6 Work order # 24632285

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b> <u>Blackstone Environmental, Inc.</u> <b>Address:</b> <u>16292 Westwoods Business Parks Dr.</u> <b>City / State / Zip:</b> <u>Ellisville, MO 63021</u> <b>Contact:</b> <u>Tyler Huff</u> <b>Phone:</b> <u>(314) 392-7870</u> <b>E-Mail:</b> <u>thuff@blackstone-env.com</u> <b>Fax:</b> _____	<b>Samples on:</b> <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input checked="" type="checkbox"/> NO ICE <span style="margin-left: 20px;">N/A °C</span> <span style="float: right;">LTG#</span> <b>Preserved in:</b> <input checked="" type="checkbox"/> LAB <input type="checkbox"/> FIELD <span style="float: right;"><b>FOR LAB USE ONLY</b></span> <b>Lab Notes</b>  <b>Client Comments:</b>
--	--

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous? If yes, include details of the hazard.  Yes  No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section.  Yes  No

Project Name/Number <i>3649</i>		Sample Collector's Name <i>Tyler Huff</i>		MATRIX										INDICATE ANALYSIS REQUESTED									
				Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW/Lead													
Results Requested		Billing Instructions	# and Type of Containers																				
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)			UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER													
Lab Use Only	Sample Identification	Date/Time Sampled																					
<i>24032285001</i>	<i>B-Ann-S1</i>	<i>3.28.2024 @ 7:05</i>																					
<i>002</i>	<i>B-Ann-S2</i>	<i>7:06</i>																					
<i>003</i>	<i>B-Ann-S3</i>	<i>7:07</i>																					
<i>004</i>	<i>B-Ann-S4</i>	<i>7:08</i>																					
<i>005</i>	<i>B-Ann-S5</i>	<i>7:08</i>																					
<i>006</i>	<i>B-Ann-S6</i>	<i>7:12</i>																					
<i>007</i>	<i>B-Ann-S7</i>	<i>7:12</i>																					
<i>008</i>	<i>B-Ann-S8</i>	<i>7:13</i>																					
<i>009</i>	<i>B-Ann-S9</i>	<i>7:13</i>																					
<i>010</i>	<i>B-Ann-S10</i>	<i>7:14</i>																					
Relinquished By		Date/Time	Received By										Date/Time										
<i>Tyler Huff</i>		<i>3/28/2024 @ 9:45</i>	<i>Whitney Dyer</i>										<i>3/28/24 9:45</i>										

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 88156





# CHAIN OF CUSTODY

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b> <u>Blackstone Environmental, Inc.</u> <b>Address:</b> <u>16292 Westwoods Business Parks Dr.</u> <b>City / State / Zip:</b> <u>Ellisville, MO 63021</u> <b>Contact:</b> <u>Tyler Huff</u> <b>Phone:</b> <u>(314) 392-7870</u> <b>E-Mail:</b> <u>thuff@blackstone-env.com</u> <b>Fax:</b> _____	<b>Samples on:</b> <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE °C <span style="float: right;">LTG#</span> <b>Preserved in:</b> <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <span style="float: right;"><b>FOR LAB USE ONLY</b></span> <b>Lab Notes</b>  <b>Client Comments:</b>
--	--

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous? If yes, include details of the hazard.  Yes  No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section.  Yes  No

Project Name/Number		Sample Collector's Name		MATRIX										INDICATE ANALYSIS REQUESTED																	
3649		Tyler Huff		Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead																					
Results Requested		Billing Instructions									# and Type of Containers																				
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)				UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER																				
Lab Use Only	Sample Identification	Date/Time Sampled																													
24032285 021	B-Ann-S21	3.28.2024 @ 7:30																													
022	B-Ann-S22	7:30																													
023	B-Ann-S23	7:31																													
024	B-Ann-S24	7:36																													
025	B-Ann-S25	7:36																													
026	B-Ann-S26	7:37																													
027	B-Ann-S27	7:37																													
028	B-Ann-S28	7:38																													
029	B-Ann-DF29	7:42																													
030	B-Ann-DF30	7:42																													
Relinquished By			Date/Time			Received By			Date/Time																						
						Whitney Deane			3/28/24 9:45																						

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

BottleOrder: 85761







# CHAIN OF CUSTODY

pg. 6 of 6

Work order # 24032285

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Blackstone Environmental, Inc.

**Address:** 16292 Westwoods Business Parks Dr.

**City / State / Zip:** Ellisville, MO 63021

**Contact:** Tyler Huff **Phone:** (314) 392-7870

**E-Mail:** thuff@blackstone-env.com **Fax:** \_\_\_\_\_

**Samples on:**  ICE  BLUE ICE  NO ICE °C LTG#

**Preserved in:**  LAB  FIELD **FOR LAB USE ONLY**

**Lab Notes**

Are these samples known to be involved in litigation? If yes, a surcharge will apply. Yes No

Are these samples known to be hazardous? If yes, include details of the hazard. Yes No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. Yes No

**Client Comments:**

Project Name/Number		Sample Collector's Name		MATRIX										INDICATE ANALYSIS REQUESTED																
Results Requested		Billing Instructions		# and Type of Containers										Aquous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead										
<input type="checkbox"/> Standard	<input type="checkbox"/> 1-2 Day (100% Surcharge)			UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER																			
<input type="checkbox"/> Other	<input type="checkbox"/> 3 Day (50% Surcharge)																													
Lab Use Only	Sample Identification	Date/Time Sampled																												
24032285	B-2-551	3.28.2024 @ 8:18																		X										
057	B-2-DF52	8:20																												
053	B-2-DF53	8:21																												

Relinquished By	Date/Time	Received By	Date/Time
		<i>Whitney O'Neil</i>	3/28/24 9:45

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 88156

